



ANSI/AIHA Z9.2-2006

American
National
Standard
for

**Fundamentals
Governing the
Design and
Operation of
Local Exhaust
Ventilation
Systems**



A Publication by
American Industrial Hygiene Association

ANSI/AIHA Z9.2—2006

**American National Standard —
Fundamentals Governing
the Design and Operation of
Local Exhaust Ventilation Systems**

Secretariat

American Industrial Hygiene Association

Approved: August 18, 2006

American National Standards Institute, Inc

American National Standard

Approval of an American National Standard requires verification by ANSI that the requirement for due process, consensus, and other criteria for approval have been met by the standard's developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objection be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary. Their existence does not in any respect preclude anyone, whether he or she has approved the Standards, or not, from manufacturing, marketing, purchasing, or using products, processors, or procedures not conforming to the Standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this Standard no later than five years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by
American Industrial Hygiene Association
2700 Prosperity Ave., Suite 250
Fairfax, VA 22031
www.aiha.org

Copyright © 2006 by the American Industrial Hygiene Association
All rights reserved.

No part of this publication may be reproduced in any form,
in an electronic retrieval system or otherwise, without the
prior written permission of the publisher.

Printed in the United States of America.

Stock No: IVEA07-720
ISBN: 978-1-931504-73-7

Contents

	Page
Foreword	iii
Committee Members.....	iv
1. Scope.....	1
2. Referenced Standards and Publications	2
3. Definitions	4
4. General Requirements.....	7
5. Plant Layout and Construction.....	10
6. Makeup Air Systems.....	13
7. Exhaust Hoods	17
8. Ductwork and Stacks	21
9. Air Cleaning Equipment.....	25
10. Fans and Air Moving Devices	26
11. Management of LEV systems.....	29
12. Commissioning	30
13. Operations and Maintenance.....	32
14. Testing, Balancing, and Operational Checks.....	34

Appendices

A. Commentary by Standard Section Number.....	37
B. ANSI Z9.2 Audit Form.....	51

This is a preview of "ANSI/AIHA Z9.2-2006". [Click here to purchase the full version from the ANSI store.](#)

FOREWORD (This foreword is not part of the American National Standard/AIHA Z9.2-2006)

This standard describes fundamental good practices related to the commissioning, design, selection, installation, operation, maintenance, and testing of local exhaust ventilation (LEV) systems used for the control of employee exposure to airborne contaminants. It is intended for use by LEV system owners, employers, industrial hygienists, facility engineers, maintenance personnel, testing and balancing personnel, ventilation system designers, and others with responsibility for LEV systems. It is compatible with the ACGIH Industrial Ventilation Manual and other recognized standards of good practice.

A document describing fundamentals of exhaust system design was originally published in 1936. This was formalized by the Z9 Committee under the direction of Knowlton Caplan, and published in 1960, with updates in 1971 and 1979. The present edition constitutes a major revision of the document. Under the leadership of Jeff Burton, the Z9.2 subcommittee has developed a more performance based document with a systems orientation that should appeal to a wider audience. Much of the previously included technical design detail has been left to other, more thorough and comprehensive sources.

HOW TO READ THIS STANDARD:

The standard is presented in two column format. The left column presents the requirements of the standard; the right column provides clarification and explanation of the requirements plus "*how to comply*" information. Appendix A provides supplementary information by Standard section number. The letter "(A)" at the end of a section designates an Appendix A entry for that section.

Requirements should be considered minimum criteria and can be adapted to the needs of the User establishment. Demonstrably equal or better approaches are acceptable. When deviating from the Standard, documentation should be provided. The Standard is auditable by those trained in local exhaust ventilation. An Audit Form is provided in Appendix B.

Suggestions for improvement of this standard are welcome. The Committee will carefully consider all comments and suggestions. Comments should be sent to Attn: Scientific and Technical Initiatives, AIHA, 2700 Prosperity Avenue, Suite 250, Fairfax, VA 22031.

ANSI/AIHA Z9.2-2006

This standard was processed and approved for submittal to ANSI by the Z9 Accredited Standards Committee on Health and Safety Standards for Ventilation Systems. Committee approval of the Standard does not necessarily imply that all committee members voted for its approval. At the time it approved this Standard the Z9 Committee had the following members:

J. Lindsay Cook, Chair
L. DiBerardinis, Vice Chair
Mili Mavely, Secretariat Representative

Organization Represented

Name of Representative

Alliance of American Insurers	S. Ecoff
American Chemical Society	D. Walters
American Conference of Governmental Industrial Hygienists	G. Knutson
American Automobile Manufacturers Assoc.	G. M. Adams
American Foundrymen's Society	R. Scholz
American Glovebox Society	S. Crooks
American Society of Heating, Refrigerating, and Air Conditioning Engineers	H. F. Behls
Chemical Industry Institute of Toxicology	J. L. Cook
Massachusetts Institute of Technology	L. J. DiBerardinis
National Association of Metal Finishers	K. C. Hankinson
National Institute of Occupational Safety and Health	J. W. Sheehy
U. S. Department of Labor	
Occupational Safety and Health Administration	I. Wainless

Individual Members

D. Blackburn	K. Paulson
D.J. Burton	J.M. Price
C. Figueroa	J.C. Rock
S.J. Gunsel	M. Rollins
R.L. Karbowski	D.R. Scarbrough
M. McManus	T.C. Smith
D. O'Brien	L.K. Turner

Subcommittee Z9.2 on Local Exhaust Systems, which developed this standard, had the following members:

D. Jeff Burton, Chair	L.K. Turner
G.M. Adams	J. Throckmorton
K. Paulson	S. Chesney
J.C. Rock	S. Swanson
T.C. Smith	R.T.Hughes
C. Figueroa	

American National Standard — Fundamentals Governing the Design and Operation of Local Exhaust Ventilation Systems

Requirements of the Standard

1. Scope

1.1 This Standard establishes minimum requirements for the commissioning, design, specification, construction, and installation of fixed industrial local exhaust ventilation (LEV) systems used for the reduction and prevention of employee exposure to harmful airborne substances in the industrial environment.

1.2 The Standard also establishes fundamental requirements for the management, operation, maintenance, and testing of LEV systems to assure satisfactory performance over the life of the system.

1.3 The Standard also describes basic requirements for replacing air exhausted from the space.

1.4 The Standard does not cover:

- ventilation for comfort,
- air moving systems which are part of an industrial process,
- paint booths not used primarily for employee protection, or
- energy conservation,

except when they also impact or apply to airborne contaminant control for employee protection.

1.5 Where Standard provisions are in conflict, the more stringent shall apply.

Clarification and Explanation of the Requirements

1. Scope

1.1 Local exhaust ventilation is an important engineering control technique for maintaining acceptable air quality in the industrial work environment. Its major approaches are the capture, control, or containment of airborne contaminants at or as close as possible to the point of contaminant generation. LEV is often used with other control methods, e.g., isolation, dilution ventilation, or personal protective equipment. Properly designed, installed and operated, LEV systems can provide excellent control of airborne contaminants.

1.3 Replacement air systems that are improperly designed, installed or operated can impair otherwise-acceptable LEV systems.

1.4 No ventilation standard can provide complete and comprehensive coverage of every application and technical problem encountered when applying LEV systems to the wide range of processes and equipment found in industry. The User should refer to appropriate technical references and publications for further guidance on uses and applications of local exhaust in specific applications. (A)

1.5 Because some sections are written to stand alone, they may duplicate requirements of other sections. Efforts to avoid